



Agreement for Trenching and Underground Service

The undersigned member is requesting KREMC to place its electric wires underground. To comply with this request, the member agrees to meet the following conditions:

1. **If Applicable**, the member shall obtain the necessary Right-of-Way easements for installing, maintaining, and replacing the underground wire.
2. The meter base must be installed at a KREMC-approved location. The member's installer must install the proper size Schedule 80 PVC conduit per metering application, which will extend from the meter base to 18 inches below ground level. Remove soil, concrete, or other debris obstructing the conduit from being straight or plumb with the structure.
3. The member's installer must install the proper size ground wire and two ground rods.
4. The service entrance main breaker must be incorporated next to the meter base, or inside mounted back-to-back of the meter base, or located in the basement directly below the meter base. No other location is permitted.
5. KREMC will furnish and install the underground wire and connect it to the line side of the meter base.
6. The trench route will be in a straight line, where possible, from the transformer or lift pole to the meter base.
7. The undersigned acknowledges there is the possibility of damage to lawns, shrubs, underground pipes, wires, tanks, fences, siding, walkways, tiles, etc. Understanding this, the undersigned hereby elects to request underground service and agrees **not to hold KREMC (or its contractor)** liable for any costs or damages which may be incurred while trenching for, installing, or maintaining the underground wire.

The undersigned agrees to advise KREMC (and its contractors) of the **exact location** of any underground pipes, tiles, wires, tanks, etc. The undersigned further agrees to assume all liability for damage or costs arising from incorrect advice of locations.

8. KREMC will backfill the trench, leaving sufficient soil over the trench to allow for normal settling. Member will add fill as trench settles.
9. Member shall provide conduit where necessary. (Driveways, etc.)
10. The member will clear a 12-ft. wide path in heavily wooded areas separate from the driveway.

Account Name: _____

Service Location: _____

Map/Pole Number: _____

Service Order # _____

Locate # _____

Member/Landowner/Contractor

Date

KREMC Representative

Date